CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

NABL - Accredited Laboratory as per ISO / IEC-17025 :2005

T-2377

Job No.: CTCE/BBMP/AEW/W.No.08/CSR-2/756c/CUBE/2014-15 20.02.2015

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

*** Customer** : **Asst. Executive Engineer,** Kodigehalli Sub Division, BBMP, Bangalore.

*** Agency** : **M/s. Annapoorneshwari Engineering Works,** Bangalore.

***Name of the work** : Providing Cement Concrete to Roads at Kodigehalli Thindlu Main road (near Sundresh Residency) and 21st B cross, 2nd main C Block, Sahakaranagar link Road (Ganesha Residency) in Ward No.08, Kodigehalli Sub Division, BBMP, Bangalore.

***Sample ID** : Pavement Concrete

Size of cubes : 150mmx150mmx150mm

Cross Sectional Area : 22500 mm^2

Technical Reference : IS: 516-1959 (Reaffirmed 2008)

***Grade of Concrete** : M_{20}

Compressive Strength as on : 7th day

Sample Received on : 20.02.2015

AE-8

2

Sl.No.	*Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	13.02.2015	20.02.2015	8.123	323.5	14.38
2	13.02.2015	20.02.2015	8.256	335.8	14.92
3	13.02.2015	20.02.2015	8.369	352.6	15.67

*Information is furnished by the Customer/Representative.

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

Civil-Tech Consultants & Engineers Bangalore

****

VISHWANATH. I.A.
Chief Executive Officer

Assistant Executive Engineer,
Kodigehalli Sub Division,
Yelahanka Zone, B.B.M.P.,
Bangalore.

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakthi Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.
Tele Fax : 23223227, Website : www.civiltechconsultants.com
E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com

CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

NABL - Accredited Laboratory as per ISO / IEC-17025 :2005

T-2377

Job No.: CTCE/BBMP/AEW/W.No.08/CSR-2/756c/CUBE/2014-15 20.02.2015

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

*** Customer** : **Asst. Executive Engineer,** Kodigehalli Sub Division, BBMP, Bangalore.

*** Agency** : **M/s. Annapoorneshwari Engineering Works,** Bangalore.

***Name of the work** : Providing Cement Concrete to Roads at Kodigehalli Thindlu Main road (near Sundresh Residency) and 21st B cross, 2nd main C Block, Sahakaranagar link Road (Ganesha Residency) in Ward No.08, Kodigehalli Sub Division, BBMP, Bangalore.

***Sample ID** : Pavement Concrete

Size of cubes : 150mmx150mmx150mm

Cross Sectional Area : 22500 mm^2

Technical Reference : IS: 516-1959 (Reaffirmed 2008)

***Grade of Concrete** : M_{20}

Compressive Strength as on : 7th day

Sample Received on : 20.02.2015

Sl.No.	*Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	13.02.2015	20.02.2015	8.265	335.4	14.91
2	13.02.2015	20.02.2015	8.374	342.7	15.23
3	13.02.2015	20.02.2015	8.468	356.8	15.86

*Information is furnished by the Customer/Representative.

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

****

VISHWANATH. I.A.
Chief Executive Officer

Assistant Executive Engineer,
Kodigehalli Sub Division,
Yelahanka Zone, B.B.M.P
Bangalore

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakthi Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.
Tele Fax : 23223227, Website : www.civiltechconsultants.com
E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com

CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

NABL - Accredited Laboratory as per ISO / IEC-17025 :2005

T-2377

Job No.: CTCE/BBMP/AEW/W.No.08/CSR-2/756c/CUBE/2014-15 21.02.2015

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

*** Customer** : **Asst. Executive Engineer,** Kodigehalli Sub Division, BBMP, Bangalore.

*** Agency** : **M/s. Annapoorneshwari Engineering Works,** Bangalore.

***Name of the work** : Providing Cement Concrete to Roads at Kodigehalli Thindlu Main road (near Sundresh Residency) and 21st B cross, 2nd main C Block, Sahakaranagar link Road (Ganesha Residency) in Ward No.08, Kodigehalli Sub Division, BBMP, Bangalore.

***Sample ID** : Pavement Concrete

Size of cubes : 150mmx150mmx150mm

Cross Sectional Area : 22500 mm^2

Technical Reference : IS: 516-1959 (Reaffirmed 2008)

***Grade of Concrete** : M_{20}

Compressive Strength as on : 7th day

Sample Received on : 21.02.2015

Sl.No.	*Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	14.02.2015	21.02.2015	8.275	345.6	15.36
2	14.02.2015	21.02.2015	8.496	368.9	16.40
3	14.02.2015	21.02.2015	8.347	357.3	15.88

*Information is furnished by the Customer/Representative.

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

****

VISHWANATH. I.A.
Chief Executive Officer

Assistant Executive Engineer.
Kodigehalli Sub Division,
Yelahanka Zone, B.B.M.P
Bangalore.

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakthi Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.
Tele Fax : 23223227, Website : www.civiltechconsultants.com
E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com

CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

NABL - Accredited Laboratory as per ISO / IEC-17025 :2005

T-2377

Job No.: CTCE/BBMP/AEW/W.No.08/CSR-2/756c/CUBE/2014-15 21.02.2015

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

*** Customer** : **Asst. Executive Engineer,** Kodigehalli Sub Division, BBMP, Bangalore.

*** Agency** : **M/s. Annapoorneshwari Engineering Works,** Bangalore.

***Name of the work** : Providing Cement Concrete to Roads at Kodigehalli Thindlu Main road (near Sundresh Residency) and 21st B cross, 2nd main C Block, Sahakaranagar link Road (Ganesha Residency) in Ward No.08, Kodigehalli Sub Division, BBMP, Bangalore.

***Sample ID** : Pavement Concrete

Size of cubes : 150mmx150mmx150mm

Cross Sectional Area : 22500 mm^2

Technical Reference : IS: 516-1959 (Reaffirmed 2008)

***Grade of Concrete** : M_{20}

Compressive Strength as on : 7th day

Sample Received on : 21.02.2015

Sl.No.	*Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	14.02.2015	21.02.2015	8.395	347.4	15.44
2	14.02.2015	21.02.2015	8.274	336.7	14.96
3	14.02.2015	21.02.2015	8.462	355.9	15.82

*Information is furnished by the Customer/Representative.

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

****

VISHWANATH. I.A.
Chief Executive Officer

Assistant Executive Engineer,
Kodigehalli Sub Division,
Yelahanka Zone, B.B.M.P.

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakthi Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.
Tele Fax : 23223227, Website : www.civiltechconsultants.com
E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com